



Certificate number: 2308783 (2)

Issued 04/07/2024

Expires 31/08/2028

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Steve Leigh & Associates Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Steve Leigh & Associates Ltd
3 Fairways
Stuston
Diss
Suffolk
IP21 4AB
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2308783

The following products belong to this certificate

<p>PRODUCT DESCRIPTION Range of single check valves housed within plastic bodies. Some models incorporate flow regulators. ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) NRv2 Check Valve Assembly – Nominal Diameter 20mm – DN20 NRv2 Check Valve Assembly Lo-Flo – Fixed Flow Rate 12 litres/min (red) NRv2 Check Valve Assembly Lo-Flo – Fixed Flow Rate 14 litres/min (pink) NRv2 Check Valve Assembly Lo-Flo – Fixed Flow Rate 10 litres/min (light blue)</p>
<p>SIZE: Nominal Diameter 20mm – DN20.</p>
<p>SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature: Cold Water Use Only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.</p>
<p>MARKING NRV on body.</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES N/A.</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements. Proviso: This backflow prevention device (single check valve) has passed all available tests, however includes a housing/body or connection type that is not referenced in the UK Regulators Specification or the relevant product standard EN 13959. Due to the absence of an appropriate specification for these housing/body or connection types or the EN Standard being updated to include these connection types, the installation of these products is subject to the acceptance of the Local Water Authority or Water Company, and these should be contacted before installation.</p>

Extra Notes