

Certificate
2608727 (1)



Issued 18/08/2026
Valid until 18/08/2031

Kiwa UK Regulation 4 (KUKreg4) Approval

Kiwa hereby declares that legitimate confidence exists in the products specified and model number(s) listed in the Appendix for:

Steve Leigh & Associates Ltd

meets the requirements as described in the
Evaluation Guideline – Kiwa UK – EG004 (Issue 7) – Regulation 4(1)(a)

Which verifies the requirements of reference standard(s):

Regulation 4(1)(a) of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification and is only valid in combination with the appendix.

David Jay
Business Unit Manager- Authorised
Signatory Kiwa Limited (Watertec)

This certificate relates to products intended to be used in the UK only. For other countries, other (National) requirements will apply.

Disclosure of the certificate is permitted in full.

To check the validity of a certificate, scan the QR code or go to <https://www.kiwa.com/gb/en-gb/about-kiwa/water-products/>



KUKreg4

Appendix

The following products belong to this certificate

PRODUCT DESCRIPTION Wall mounted water box with plastic body.. ATS3 – Without Production Surveillance.
MODEL(S) Groundbreaker Mk3 wall mounted meter box
SIZE: 25mm compression
SCOPE: Manufacturer recommended maximum working pressure 12.0 Bar & maximum operating temperature cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only
MARKING Groundbreaker on adhesive label on case.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes