



Certificate number: 2309799 (1)

Issued 02/10/2023

Expires 22/09/2028

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Steve Leigh & Associates Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Steve Leigh & Associates Ltd.
3 Fairways
Stuston
Diss
Suffolk
IP21 4AB
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2309799

The following products belong to this certificate

| |
|---|
| PRODUCT DESCRIPTION Range of in-line non-return valves with plastic bodies, fitted with flow restrictors. ATS3 – Without Production Surveillance. |
| MODEL(S) In Line Lo-Flo Assembly– Fixed Flow Rate 12 litres/min (red) In Line Lo-Flo Assembly – Fixed Flow Rate 14 litres/min (pink) In Line Lo-Flo Assembly – Fixed Flow Rate 10 litres/min (light blue) |
| SIZE: See model. |
| SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water. |
| MARKING Lo-Flow, flow arrow on body. |
| MATERIALS Non-metallic materials assessed (BS6920) to point of discharge. |
| BACKFLOW PROTECTION NOTES N/A. |
| ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements. No verification has been made on the flow rate. |

Extra Notes